

SAFETY MANUAL



Multispectrum IR Flame Detector X3301/X3302



SAFETY-CERTIFIED MODEL X3301/X3302 MULTISPECTRUM INFRARED DETECTOR

This manual addresses the specific requirements and recommendations applicable to the proper installation, operation, and maintenance of all Safety-Certified (SIL-Certified) X3301/X3302 Multispectrum Infrared Flame Detectors. The safety function of the X3301/X3302 is to detect a variety of fires and to provide present alarm status to its relay, analog or LON outputs. For complete information regarding performance, installation, operation, maintenance, and specifications, refer to the appropriate instruction manual:

X3301 95-8704
X3302 95-8768

QUALITY POLICY STATEMENT

All quality assurance control measures necessary for safety management as specified in IEC 61508 Part 1 have been implemented. The quality management system of Det-Tronics is based on the requirements of EN ISO 9001 and ANSI/ASQC Q9001 through the application of the Carrier Excellence Program. In addition, the Quality Management System complies with the European ATEX Directive, EN ISO/IEC 80079-34, and supervised testing requirements per ISO 17025.



SAFETY MESSAGES

Procedures and instructions in this section may require special precautions to ensure the safety of personnel performing the operations. Information that raises potential safety issues is indicated by the word "Warning". Always read and understand these safety messages.

WARNING

The X3301/X3302 is intended for use in hazardous environments that may include explosive levels of flammable gases and vapors. This product must be properly installed, operated and maintained. Improper installation or use could result in an explosion or fire resulting in death or serious injury.

- Do not remove the detector cover in explosive environments when device power is on and circuits are live.
- Detector must be properly installed, and wiring compartment cover must be fully engaged to meet hazardous area explosion-proof/ nonincendive requirements.

DESIGN

The X3301/X3302 is a multispectrum infrared flame detector that is classified as a Type B smart device according to IEC61508. The standard model provides an isolated 4-wire, 0-20 mA output, together with on-board Alarm and Fault relay contacts. These outputs serve to indicate normal operating condition of the detector, fault, or the presence of a flame alarm. The X3301/X3302 contains extensive self-diagnostics and is programmed to send the current output to a specified state (1 mA, 2 mA or 3 mA) upon internal detection of a failure or fault condition.

HART communication is available as an option. The HART option allows the operator to monitor the status of the detector, determine factory settings, adjust field settings, and initiate field tests. For complete information regarding HART communication, refer to the appropriate HART Addendum:

X3301 95-8577

X3302 95-8613

When using the 0-20 mA output with HART as a safety output, it is required that Write Protect be set to "on" to ensure that the HART is non-interfering.

NOTE

All configuration changes to the X3301/X3302 must be verified by the user via a proof test, power cycle and re-check of settings, or other appropriate method.

The EQP model is designed for use exclusively with the Det-Tronics Eagle Quantum Premier system. The detector communicates with the system controller over a digital communication network or EQPSL/SLC (Eagle Quantum Premier Safety Loop / Signalling Line Circuit). The EQPSL/SLC is a fault tolerant, two wire digital communication network arranged in a loop configuration. Analog and relay outputs are not available on this model. For information regarding the use of the SIL 2 Certified X3301/X3302 in an EQP system, refer to the EQP Safety Manual 95-8599.

The X3301/X3302 is designed for operation with a supply voltage from 18-30 volts DC. Proper operation outside this range cannot be assumed.

Safety-Certification of the X3301/X3302 includes:

- Analog Output
- Relay Output
- EQP LON Output version for X3301 only
- HART Output as non-interfering
- xWatch Surveillance Camera output as non-interfering*

Safety-Certification of the X3301/X3302 does **not** include:

- Pulse Output
- RS-485 Modbus signal
- EQP LON Output version for X3302

* The xWatch Surveillance Camera has been evaluated as a non-interfering device and is approved for use with a Safety-Certified X3301/ X3302. The xWatch camera can be attached directly to the X3301/X3302 through a factory installed integral connection adapter. The addition of the xWatch does not affect the safety performance of the X3301/X3302. Refer to manual number 95-8603 for details regarding the xWatch camera.

VALID INPUT RANGE

X3301/X3302 fault annunciation is provided on the 0-20 mA signal output loop by signaling to a 1 mA, 2 mA, or 3 mA current output level. The receiving device must be programmed to indicate a fault condition when current levels reach over-current (≥ 21 mA) or undercurrent (≤ 3.6 mA).

DIAGNOSTIC RESPONSE TIME

NOTE

The X3301/X3302 analog signal and relay outputs are not safety-rated during detector warm-up or signal output loop testing (including proof testing). Alternative means should be used at the job site to ensure facility safety during these activities.

The X3301/X3302 will perform all critical diagnostic functions within 58 minutes, worst case diagnostic detection time. The user must not configure the automatic **oi** test interval and failure annunciation count combination to be greater than 58 minutes (default setting is one minute intervals, with failure annunciation after three failed **oi** tests).

OPTICAL INTEGRITY TEST

The **oi** test is designed to generate a fault when the unit's detection range has been reduced by 50% or more. This factor should be carefully considered during detector placement with regard to the required safety function.

CERTIFICATION

The X3301/X3302 Safety-Certified version is certified to IEC61508:2010 for single input use in low demand SIL 2 Safety Instrumented Systems.

SAFETY-CERTIFIED PRODUCT IDENTIFICATION

Safety Certification of all X3301/X3302 models meeting SIL 2 safety standards is clearly identified on the product label.

INSTALLATION

NOTE

For complete information regarding performance, installation, operation, maintenance and specifications, refer to the appropriate instruction manual:

X3301 95-8704
X3302 95-8768

Tools Required:

- 14 mm hexagonal wrench

No special installation requirements exist above and beyond the standard installation practices documented in the instruction manual. Environmental specification limits are also as published in the general specifications section in the instruction manual.

The operating power distribution system must be designed and installed so the terminal voltage does not drop below 18 Vdc when measured at any specific location. The maximum current limit must be less than 2 amperes. The external system providing power to the X3301/X3302 must have overvoltage protection that ensures supply voltage does not exceed 33 Vdc.

Common Misuse Scenarios

Refer to the General Application Information section of the instruction manual for detailed information on common misuse scenarios. Application environment considerations include the following:

- Intense IR sources should not be present in detection area.

NOTE

The above scenarios will cause the X3301/X3302 relay or 4-20 mA outputs to announce a high background fault and/or false alarm depending on the intensity of the radiation and the relay configuration.

- Glass and Plexiglas windows attenuate radiation and should not be located between the detector and detection area.
- The detector must have a direct line-of-sight to any potential flame source in the detection area. Care must be taken to keep physical obstructions out of the line of view of the detector.
- The multispectrum IR flame detectors are to be installed in locations where the risk of mechanical damage is low.

NOTE

If the user suspects that damage or misuse has occurred to the X3301/X3302, a full proof test shall be performed.

NOTE

The black plastic shipping cap must be removed prior to placing the detector into service.

START-UP AND COMMISSIONING

All safety functions of the X3301/X3302 are active within 30 seconds of power-up without any user action required.

Commissioning Personnel

The Safety Certified X3301/X3302 Flame Detector can be commissioned by any qualified person with knowledge of flame detection instruments and the configuration device being used. Refer to the Start-Up section provided in the instruction manual.

Relay Configuration Requirements

The end user must provide transient and current limiting on the output contacts of the relays. The maximum relay contact output must be limited to 2 amperes at 30 Vdc. The load must be a resistive load. The user must protect against transients by using standard protection methods such as proper grounding of shielded wire and separation of relay load wires from other lines carrying rapidly switched high current (e.g. large motor power supply lines).

If the 0-20 mA analog output is not being monitored for fault conditions, the status of the Fault relay must be monitored and appropriate action taken. The fault relay is configured for normally energized operation.

Configuration

Digital communication with the X3301/X3302 can be used to monitor internal status and to modify the factory settings. For specific information regarding HART communication, refer to the appropriate HART Addendum:

X3301 95-8577
X3302 95-8613

NOTE

Prior to device configuration (setting alarm thresholds, latch/non-latch function, etc.) all alarm outputs must be bypassed. The device is not safety certified during configuration change activities.

NOTE

All configuration changes to the X3301/X3302 must be verified by the user via a proof test, power cycle and re-check of settings, or other appropriate method. The LED flash rate during power-up should be checked to verify proper setting.

Configuration Protection

When using the 0-20 mA output with HART as a safety output, it is required that Write Protect be set to “on” to ensure that the HART is non-interfering. If HART Write Protect is temporarily disabled, the user must take specific action to re-enable Write Protect to ensure that HART communication remains non-interfering.

OPERATION, MAINTENANCE, INSPECTION AND PROOF TESTING

Tools Required:

- Magnetic **o_i** test tool (p/n 102740-002)
- Window cleaner (p/n 001680-001 or isopropanol)
- Lens tissue and cotton swabs
- 4 mm flat blade screwdriver

After normal installation and start-up have been completed as recommended within the instruction manual, Proof Tests must be performed for every Safety-Certified X3301/X3302 detector installed.

Personnel performing Proof Test procedures shall be competent to perform the task. All Proof Test results must be recorded and analyzed. Any corrective actions taken must be documented in the event that an error is found in the safety functionality. The Proof Tests must be performed at a frequency as shown in Table 1.

WARNING

Failure to perform the specified testing and inspection may lower or void the SIL rating for the product or system.

Table 1—Frequency of Proof Tests

Proof Test Name	Commissioning	Frequency
Visual Field Inspection Proof Test	Yes	As needed, depending on level and type of contaminants present
Detector Response Magnetic o_i / Manual o_i Proof Test	Yes	Yearly

VISUAL FIELD INSPECTION PROOF TEST

Visual inspection of all Safety-Certified X3301/X3302 Flame Detectors shall be conducted as needed to confirm that there are no obstructions in the optical field of view. Corrective action will include removal of such impediments should they exist.

Completion of Visual Field Inspection Proof test will be recorded and documented in the SIS logbook.

DETECTOR RESPONSE PROOF TEST



WARNING

Any external alarm equipment, systems or signaling devices that could be automatically initiated by performing this test must be disabled or bypassed before performing this test!

Tools Required:

- Magnetic **oi** test tool (part number 102740-002), HART Communicator, or hard wire trigger capability

All flame detectors must be performance tested using the Magnetic **oi** / Manual **oi** Procedure and inspected to ensure that they are capable of providing expected performance and protection. Manual **oi** tests may be initiated via EQP communication, hard wire trigger or HART communication. Note that the Mag **oi** Procedure and Manual **oi** Tests are not interference free. During these tests the unit is not performing normal flame detection functions. Model X3301/X3302 provides an onboard status LED, which indicates Green color when internal operational parameters are normal. See instruction or HART manuals for details on performing Mag and Manual **oi** tests.

To indicate a successful proof test, the LED changes to a red color, the Alarm and Auxiliary relays change state to indicate an alarm condition, and the current output indicates 20 mA. These results should be verified on the control device.

To indicate an unsuccessful proof test, the LED changes to yellow, the Fault relay becomes de-energized, and the current output indicates 2 mA. The fault indication can be reset by momentarily applying the magnet or manual **oi** switch.

FAULT/FAILURE ACTION PLAN

In the event of a non-alarm condition result with the Mag **oi** test, the standard Maintenance and Troubleshooting procedures listed in the X3301/X3302 instruction manual must be followed. In the event that the condition cannot be resolved, the standard Device Repair and Return procedures listed in the X3301/X3302 instruction manual must be followed.

Any and all failures to successfully complete the alarm test must be recorded and documented in the SIS logbook.



WARNING

Any external alarm equipment, systems or signaling devices that were disabled must be re-activated at the conclusion of proof testing activities.

PRODUCT REPAIR

The X3301/X3302 is not field-repairable, and any internal device repairs must be conducted at the factory. No firmware changes are permitted or authorized. All failures indicated by internal diagnostics or Proof Tests that cannot be resolved through the troubleshooting and maintenance procedures described in the X3301/X3302 manual must be reported to the manufacturer.

OPERATING, ENVIRONMENTAL AND PERFORMANCE SPECIFICATIONS

The operating temperature range for the Safety Certified X3301/X3302 is -40°C to $+75^{\circ}\text{C}$. The Safety-Certified X3301/X3302 product versions fully comply with, and must be operated in accordance with the functional and performance specifications provided in the instruction manual. A 24 hour mean time to repair should be assumed for safety availability calculations.

SPARE PARTS

Refer to the spare parts section of the X3301/X3302 manual. Safety certification is based on a sufficient number of spares to achieve a 24 hour mean time to repair.

CERTIFICATION AND FAILURE RATE DATA

All Safety-Certified X3301/X3302 models are certified compliant to:

IEC61508: 2010

Type B Device

Systematic Capability: SIL 2 certified

HFT: 0

Low Demand Mode

PFDavg should be calculated for any safety instrumented function using the X3301/X3302. (Refer to FMEDA report for necessary information, including DU rate).

Safety Accuracy: Not applicable.

Safety Response Time: See appendix A of the instruction manual for response time details.

Product Life (Typical): 25 years @ 40°C
12 years @ 75°C

(Based on database 217 Plus, Version 2, 'Industrial' profile).

All failure rate data for SIL verification is in the FMEDA report, which is available upon request.

Product Certifications



FM, CSA, ATEX, CE, exida, and others.

Refer to the X3301/X3302 Instruction Manual for details.

FMEDA Report available.

For complete information regarding performance, installation, operation, maintenance, and specifications, refer to the instruction manual:

X3301 95-8704
X3302 95-8768

IEC 61508 Failure Rates in FIT¹

Failure Category	λ_{sd}	λ_{su}^2	λ_{dd}	λ_{du}	SFF ³
X3301/X3302 IR Flame Detector, 0-20 mA Output	0 FIT	106 FIT	920 FIT	75 FIT	93.2%
X3301/X3302 IR Flame Detector, Relay Output	335 FIT	120 FIT	556 FIT	88 FIT	92.0%
X3301/X3302 IR Flame Detector, 0-20 mA Output with HART	0 FIT	110 FIT	1146 FIT	93 FIT	93.1%

¹ FIT = 1 Failure / 10⁹ Hours

² It is important to realize that the No Effect failures are no longer included in the Safe Undetected failure category according to IEC 61508, ed2, 2010.

³ Safe Failure Fraction needs to be calculated on (sub)system level.

TERMS AND DEFINITIONS

EQP	Eagle Quantum Premier System
EQPSL/SLC	Eagle Quantum Premier Safety Loop / Signaling Line Circuit
FMEDA	Failure Mode Effects and Diagnostics Analysis
HART	Highway Addressable Remote Transducer
HFT	Hardware Fault Tolerance
PFD	Probability of Failure on Demand (Probability of Dangerous Failure)
PFDavg	Average Probability of Failure on Demand
SFF	Safe Failure Fraction
SIF	Safety Instrumented Function
SIL	Safety Integrity Level
SIS	Safety Instrumented System
X3301/X3302	Multispectrum IR Flame Detector



FlexSonic® Acoustic
Leak Detector



X3301 Multispectrum
IR Flame Detector



PointWatch Eclipse® IR
Combustible Gas Detector



FlexVu® Universal Display
with GT3000 Toxic Gas Detector



Eagle Quantum Premier®
Safety System



© 2022 Carrier. All rights reserved.

Corporate Office
6901 West 110th Street
Minneapolis, MN 55438 USA
www.det-tronics.com

Phone: 952.946.6491
Toll-free: 800.765.3473
Fax: 952.829.8750
det-tronics@det-tronics.com