

# Safety Manual

Eagle Quantum Premier®  
SIL 2 Rated Fire & Gas System



# Table of Contents

INTRODUCTION .....	1
Quality Policy Statement.....	1
Scope .....	1
Document Structure.....	2
PRODUCT OVERVIEW .....	2
EQP System .....	2
EQP Safety System .....	2
EQP Safety Controllers.....	4
EQP Safety Devices .....	6
X3301-SIL .....	7
LS2000-SIL.....	7
PIRECL-SIL .....	7
AIM-SIL Analog Input Module.....	7
EDIO-SIL Enhanced Digital Input/Output Module .....	8
EDIO Digital Output Channel.....	8
HSDM Input Channel.....	8
HSDM Output Channel.....	8
UD10-DCU with and without CGS.....	8
EQ3760ASM.....	8
Power Supplies.....	9
S <sup>3</sup> Configuration Software .....	9
System Security.....	10
PROOF TESTING .....	12
EDIO Input Channel Proof Test.....	12
EDIO Output Channel Proof Test.....	12
HSDM Proof Test .....	12
AIM Input Channel Proof Test.....	12
ASM Apollo Loop Proof Test .....	12
X3301 Visual Field Inspection Proof Test.....	13
X3301 Magnetic o <sub>i</sub> Proof Test .....	13
LS2000 Optical Test Film Method.....	13
PIRECL Visual Field Inspection Proof Test .....	13
PIRECL Gas Response Proof Test.....	13
EQP User Logic Verification .....	13
INSTALLATION .....	14
Commissioning Personnel .....	14
SUITABLE APPLICATIONS .....	14
General Application Requirements .....	14
APPENDIX A – SUMMARY OF SAFETY RELATED DATA .....	19
APPENDIX B – EQP CONTROLLER LOGIC GATE TABLE.....	21

## Eagle Quantum Premier® SIL 2 Rated Fire & Gas System

### NOTE

*Where a definition of the term or abbreviation is given in IEC 61508-4 "Definitions and Abbreviations," the definition from the standard is given first in quotation marks, followed by further explanation if this is necessary.*

## INTRODUCTION

This safety manual describes the technical and procedural actions required to use the Det-Tronics Eagle Quantum Premier® (EQP) Safety System in safety-related applications. An example of a procedural action would be the need to maintain password protection of configuration programs, so that non-approved staff cannot modify these.

The scope of this document is limited to those actions that are required to ensure compliance with the relevant safety certifications and standards. Additional manuals and data sheets outside the scope of this document can be found on the Det-Tronics website ([www.det-tronics.com](http://www.det-tronics.com)).

The Safety Manual is approved and certified by *exida*® as part of the overall EQP Safety System. Satisfying these requirements is a necessary part of using the EQP Safety System in safety-related applications.

Failure to complete the actions described in this document would contravene the certification requirements.

Adherence to this document will only satisfy some of the requirements defined by IEC 61508 for safety-related applications.

It will be necessary to satisfy the full requirements of IEC 61508, and for Process Industry applications, the requirements of IEC 61511, in

order to use the Det-Tronics EQP Safety System in safety-related applications.

Further, it is the responsibility of the user to ensure that the EQP Safety System is suitable for the chosen application and complies with the appropriate application standards.

## QUALITY POLICY STATEMENT

All quality assurance control measures necessary for safety management as specified in IEC 61508 Part 1 have been implemented. The quality management system of Det-Tronics is based on the requirements of EN ISO 9001 and ANSI/ASQC Q9001 through the application of the Carrier Excellence program. In addition, the Quality Management System complies with the European ATEX Directive requirements per EN 13980, the International Electrotechnical Commission requirements per ODO05/V2, and the supervised testing requirements per ISO 17025.

## SCOPE

The Det-Tronics EQP Safety System is intended for use as part of a programmable electronic system as defined by IEC 61508. It is suitable for low demand safety functions up to safety integrity level 2 (SIL 2).

The safety critical functions for the EQP Safety System include the following:

- Fire input from X3301 and/or EDIO and/or AIM and/or HSDM
- Fire input from Apollo device and ASM
- Gas alarm from PIRECL and/or EDIO and/or AIM and/or UD10
- Gas alarm from LS2000 and/or EDIO and/or AIM and/or UD10
- Annunciation/Release from EDIO
- System logic for processing and mapping inputs and outputs.

The safety related functions of the EQP Safety System include the following:

- Trouble annunciation for compromised safety function by de-energizing the Controller's Trouble relay
- Digital input for lockout of inhibits.

The EQP Safety System employs a 1oo1D (i.e. 1 out of 1 with diagnostics) architecture to achieve SIL 2. EQP Safety Controllers may be used in redundant mode to increase system availability, but this is not required for the safety-related performance of the system.

Configuring and programming the EQP Safety System must be via a software program known as Safety System Software (S<sup>3</sup>).

In addition to completing the actions specifically related to the EQP Safety System, it is necessary to satisfy the wider requirements of IEC 61508. This includes such elements within the framework of the safety lifecycle, such as hazard and risk analysis and defining the safety instrumented function. This work must be carried out through appropriate and competent Safety Management procedures and staff.

## DOCUMENT STRUCTURE

This Safety Manual describes the actions that are required to use the Det-Tronics EQP Safety System in safety-related applications. This document is divided into the following sections:

### Introduction

**Product Overview** provides an overview of the Det-Tronics product range in general, and the EQP Safety products in particular.

**Proof Testing** describes the necessary proof testing.

**Suitable Applications** describes the use of the Det-Tronics EQP Safety System in practical applications. Included are failure rate data and PFDavg calculations.

**Appendix A** provides a summary of the essential data for safety applications for the Det-Tronics EQP Safety System.

**Appendix B** provides logic instructions and their restrictions for low demand SIL 2 applications.

## PRODUCT OVERVIEW

### EQP SYSTEM

The EQP System (on which the Det-Tronics EQP Safety System is based) was originally developed to meet the requirements of industrial fire and gas detection and mitigation. The system comprises (see Figure 1):

- Input / output modules
- Field devices for fire and gas detection
- Controllers which can be programmed to implement the control of the fire and gas system
- Power supplies and other miscellaneous hardware
- S<sup>3</sup> software which is used to configure the system and to generate the logic programs which will be run by the controllers
- A proprietary protocol known as Eagle Quantum Premier Safety Loop (EQPSL), which provides communication between field devices and the controllers.

### NOTE

*For additional information regarding set-up and installation of the EQP system, refer to the EQP system manual, form number 95-8533.*

### EQP SAFETY SYSTEM

The Det-Tronics EQP Safety System uses the following specifically developed components (see Figure 2):

- EQ3XXX – EQP Controller
- EQ3730EDIO – Enhanced Discrete Input/Output (EDIO) Module
- EQ3710AIM – Analog Input Module
- EQ3760ASM – Addressable Smoke Module
- X3301/2 – Multispectrum IR Flame Detector
- PIRECL – Infrared Gas Detector
- LS2000 – Line-of-Sight Infrared Gas Detector
- UD10-DCU (with or without CGS) - Universal Display
- EQ3780HSDM – High Speed Deluge Module

The data required to establish the suitability of the EQP Safety System for safety-related applications is provided in Appendix A of this Safety Manual.

EQP Safety System components and standard components can be used together. The




Figure 1—Components of a Det-Tronics EQP System

non-safety certified components are classed as non-interfering. A list of all the devices available for the EQP system is maintained at [www.det-tronics.com](http://www.det-tronics.com) and is shown below.

### Non-Interfering Modules

- EQ2400NE – Network Extender
- EQ2400PLR – Physical Layer Repeater
- 008981-001 Controller to Controller High Speed Serial Cable (Redundant Controllers Only)
- EQPSL Network Cables – Refer to cable specification information in the EQP system manual (form 95-8533).
- EQ3700DCIO – Discrete Input/Output Module
- EQ3720RM – Relay Module
- EQ3750ASH – Addressable Smoke and Heat Module
- X2200/X5200/X9800 - Flame Detectors
- EQ2200UV – Ultraviolet Flame Detector
- EQ2200UVHT – High Temperature Ultraviolet Flame Detector
- EQ2200UVIR – Ultraviolet/Infrared Flame Detector
- EQ2200DCU – Digital Communication Unit
- EQ2200DCUEX – Discrete Control Unit with Catalytic Gas Sensor
- EQ2200IDC – Initiating Device Circuit
- EQ2200IDCSC – Initiating Device Circuit Short Circuit
- EQ2500ARM – Agent Release Module
- EQ2500SAM – Signal Audible Module
- EQ2100PSM – Power Supply Monitor
- EQ2220GFM – Ground Fault Monitor
- 008056-001 – HART Interface Module
- OPECL – Open Path Eclipse Gas Detector

- UD10-DCU is SIL certified

### Non-Interfering Interfaces

- ControlNet
- Ethernet Interface Board
- EtherNet/IP™ Device Level Ring (DLR) Interface Board
- Serial Interface Board

### Configuration Software

- Det-Tronics Safety System Software (S<sup>3</sup>)




Figure 2—Det-Tronics EQP Safety System Component Overview

## EQP Safety System Component Overview

Figure 2 illustrates an overview of the role that each element of the EQP Safety System has in implementing the safety function.

### Safety Certified Product Identification

All safety certified EQP System modules are clearly identified as such on the product label.

## EQP SAFETY CONTROLLERS

The EQP Safety Controllers share a common hardware and software platform with standard EQP Controllers. The SIL rated version of the controller conducts additional diagnostic checks and annunciates additional fault conditions.

Safety compliance is assured by additional diagnostics which detect failures and take appropriate action should errors be detected.




Figure 3—Class A Pathway (isolators are optional)

If the EQP Safety Controller detects a "dangerous" fault in itself (i.e. one that would prevent the EQP Safety System from carrying out its safety function) it will de-energize the trouble relay. The fault causing the controller's trouble relay to de-energize must be investigated and corrected within the time period determined by SIF verification calculations for the particular application.

### Run Mode

Run Mode is the state in which the Det-Tronics EQP Safety System is acting as a safety-related system and carrying out its safety function. When the system is in this state, it is not possible to make modifications to configuration parameters or control logic.

### Program Mode

The system enters Program Mode when configuration parameters are downloaded to the system. The controller trouble relay is de-energized while in this mode as an indication. When the EQP System is in Program Mode, the user is responsible for maintaining a safe state.

#### NOTE

*When there is a change of configuration, the user is required to perform a validation test of the change.*

### Safe and Non-interfering Data

An EQP application program can read data from safety-related and non-interfering sources. Data from non-interfering sources must not be used in logic to block or disable safety-related signals in the safety loop. For example, data coming into the system from a non-interfering field device should not be used to block or disable an alarm output, but it could be used to activate a common alarm used by safety-related logic.

### Communication with Remote Modbus Devices

EQP Safety Controllers can read or write data to Remote Modbus devices. Any data read from such devices is not safety-related and shall not be used to block or disable safety-related logic.

### EQP Controller Inhibit Lockout

Device inhibits allow input and output signals to be blocked to allow the user to perform maintenance and testing without affecting system outputs. Example: If a flame detector is inhibited,

a flame can be presented to the detector and the fire alarm will not be registered by the controller. Subsequently, no action will be performed by the controller. Therefore inhibits are classified as a safety related issue. If a device is inhibited, it will no longer perform its safety function. For this reason, there is a global inhibit lockout feature.

Input channel four of the safety controller is designated as the inhibit lockout channel. The channel must be configured as "Inhibit Enabled" via the EQP controller configuration screen in the S<sup>3</sup> software. A normally open switch must be wired to channel four to perform the inhibit enable function. When the switch is open, changes are not allowed. When the switch is closed, inhibits can be controlled from the controller via user configured logic or from the individual device point displays on the S<sup>3</sup> software.

When the inhibit lockout switch changes state, it is logged in the EQP controller. Additionally, individual devices are logged when they are put into or taken out of the inhibit state.

It is the user's responsibility to create and enforce an appropriate lockout policy for the site.

### EQP Safety Controller Diagnostic Checks

The EQP Safety Controller automatically carries out a number of diagnostic checks on a continuous basis. A number of other diagnostic tests are also conducted to ensure the integrity of the EQPSL communication network and proper operation of the user's logic program.

All checks conducted by the controller are completed at least once an hour. This period is called the diagnostic test interval.

#### NOTE

*Other devices have different diagnostic test intervals. See EQP Safety Device Diagnostics. Be sure to account for this in calculations.*

The certifying authority that has granted the Det-Tronics EQP Safety System approval for use in low demand SIL 2 safety-related applications has confirmed the completeness of the diagnostic tests. The user program requires no additional on-line diagnostic tests. Proof testing, which is the responsibility of the user, is discussed in the "Proof Testing" section of this manual.

## Redundant EQP Safety Controllers

Using Det-Tronics EQP Safety Controllers in redundant mode will increase their availability, but will have no effect on their ability to perform a safety-related function. The redundant controller system is certified for use as part of a SIL 2 system.

When a second controller is added for redundancy, the firmware versions must match and a EQ3LTM LON termination module must be incorporated. Controllers configured for redundant operation operate in either Master or Standby mode. Refer to the EQP system manual (number 95-8533) for more details regarding controller redundancy set-up.

### NOTE

*Both the master and standby controllers must be SIL rated models. If a SIL rated controller is paired with a standard controller model, a redundancy fault will be indicated.*

## EQP SAFETY DEVICES

EQP safety rated field devices share many of the same attributes as standard EQP devices. They have the same physical form factor and are connected to the system in the same manner as standard devices. However, SIL versions of field devices are not directly interchangeable with the standard versions. Each version has a unique ID. Each field device must be configured for the proper type of device or a trouble is annunciated. SIL rated devices differ from the standard modules in that they perform additional software diagnostic checks specifically designed for safety-related applications. SIL rated controllers and EDIOs have red labels for easy identification. A mixture of SIL and non-SIL rated field devices can be used on the system at the same time, however, non-SIL rated devices shall not block or inhibit the safety function in user logic.

Self-detected failures of the diagnostics will result in a fault state where the condition is reported to the controller and annunciated to the user. Depending on the type of fault, the field device may restart and attempt to re-establish communication with the controller.

## EQPSL

The EQP controller and associated field devices are connected via the EQPSL communication loop. Only EQP system approved devices can be connected to EQPSL network (closed network). Devices from other manufacturers shall not be connected to the EQPSL. Special test pattern messages are periodically sent end to end on the EQPSL to detect faults in the transceivers and memory buffers.

Extensive diagnostics are implemented in the EQPSL to detect degraded conditions and ensure that reliable communications are available when needed to respond to a demand. This is especially important as fire and gas systems are traditionally energized to trip and it is, therefore, unacceptable for them to trip based on loss of power or network communications.

The EQPSL physical network topology is limited to a single loop which starts and ends at the Controller. The system is automatically configured to utilize less than 50% of the available bandwidth in normal operation. The additional bandwidth may be utilized by the system in transient situations involving heavy message traffic. Safety communications were evaluated in terms of probability of failure on demand consistent with an IEC 61508 low demand application.

## EQP Safety Device Diagnostics

The EQP safety devices (EDIO-SIL/AIM-SIL/X3301-SIL/LS2000-SIL/Eclipse/ASM/UD10-DCU with and without CGS) automatically carry out a number of diagnostic checks on a continuous basis. All checks are completed at least once every two hours (diagnostic test interval).

Failure of any field device diagnostic will cause the trouble relay on the controller to open. It is the user's responsibility to determine what course of action is appropriate for their situation when the controller's trouble relay opens.

The internal diagnostic tests carried out by EQP Safety devices are sufficient to meet the requirements for use in a low demand SIL 2 safety function. Proof testing, which is the responsibility of the user, is discussed in the "Proof Testing" section of this manual.

### **X3301-SIL**

The SIL EQP Model X3301 flame detectors are configured with the use of S<sup>3</sup> software and the device is safety rated at all available sensitivity settings. The fire alarm status should be used as the safety input signal for user logic. System "Proof Testing" should be conducted after any change in configuration is made.

#### **NOTE**

*Refer to the X3301 Safety Manual (number 95-8582) for specific requirements and recommendations applicable to the proper installation, operation, and maintenance of all SIL-Certified X3301 IR flame detectors.*

### **LS2000-SIL**

The SIL LS2000 Line-of-Sight Infrared Gas Detectors are configured via S<sup>3</sup> software. The device is safety rated to alarm at a user-defined percentage of the LFL – meter concentration of target gases before the concentration reaches the flammability limit.

#### **NOTE**

*Refer to the LS2000 Safety Manual (number 95-8727) for specific requirements and recommendations applicable to the proper installation, operation, and maintenance of all SIL-Certified LS2000 line-of-site gas detectors.*

### **PIRECL-SIL**

The SIL EQP Model PIRECL combustible gas detectors are configured via S<sup>3</sup> software and the device is safety rated. High and low alarm status should be used as the safety input signal for user logic. The floating point gas concentration value is available for information, but is not safety rated and should not be used as part of the safety function. System "Proof Testing" should be conducted after any change in configuration is made.

#### **NOTE**

*Refer to the PIRECL Safety Manual (number 95-8630) for specific requirements and recommendations applicable to the proper installation, operation, and maintenance of all SIL-Certified PIRECL IR gas detectors.*

### **AIM-SIL ANALOG INPUT MODULE**

The SIL AIM module is configured via S<sup>3</sup> software and the device is safety rated. High and low alarm status should be used as the safety input signal for user logic.

The SIL AIM module provides eight channels of configurable analog input. The AIM Module is specially designed to meet the requirements of IEC 61508 and expands the input capability of the Det-Tronics Eagle Quantum Premier System.

Each channel of the AIM Safety Module is an input that can accept analog devices such as gas detectors. It is the responsibility of the user to select suitable SIL rated devices to connect to the AIM.

The EQP Controller continuously monitors the status of the AIM. Input channels are supervised for out of range signals.

### **Input Range and Configuration**

The user shall enable out-of-range checking, with the out-of-range low value configured to be at least 1mA, and the out-of-range high value to be less than 24 mA and less than or equal to the connected device maximum output minus safety accuracy.

All AIM channels intended for use must be configured and downloaded from the EQP controller, otherwise they will be ignored.

For complete information regarding system overview, installation, operation, specifications, and configuration of the AIM Analog Input Module, refer to the AIM Module specification data sheet 90-1183 and/or the EQP instruction manual number 95-8533.

### **EDIO-SIL ENHANCED DIGITAL INPUT/OUTPUT MODULE**

The SIL EDIO module provides eight channels of configurable digital input or output. The EDIO Module is specially designed to meet the requirements of IEC 61508 and expands the input and output capability of the Det-Tronics Eagle Quantum Premier System. The EQP Controller continuously monitors the status of the EDIO and controls the outputs with EQPSL communications.

Each channel of the EDIO safety module can be configured as an input to accept fire detection devices such as manual alarm stations, or as an output for signaling or releasing. Both input and output circuits can be configured for supervised (line monitoring) or unsupervised operation. Channels are only SIL rated when configured for the supervised mode of operation. Unsupervised channels can be used for non-safety related

uses and are considered non-interfering. It is the responsibility of the user to select suitable SIL rated I/O devices to connect to the EDIO.

This table indicates which EDIO channel configurations are IEC 61508 SIL rated.

Definition	SIL Rated
Unsupervised Input	No
Unsupervised Output	No
Smoke Detector	No
Class A Output	Yes
Class A Input	Yes
Solenoid Output	Yes
Class A Solenoid Output	Yes
Class A Smoke Detector Input	No
Class B Output with Monitoring	Yes
Class B Input with Monitoring	Yes

Detailed information regarding the use of the EQP EDIO Safety Module is given in the appropriate data sheets and user documentation (EQP instruction manual number 95-8533). The information given here only refers to the safety-related aspects of the module.

Outputs from the EQP Safety EDIO Module are normally de-energized and are energized on command by the Controller (for example to release an extinguishant by opening a normally closed solenoid valve). Outputs will hold last state on loss of communication with the controller.

Det-Tronics S<sup>3</sup> Safety System Software is used for device configuration.

### EDIO Digital Input Channel

A change in input state is only recognized if the new input state is held for a finite time interval to ensure that noise is not incorrectly interpreted as a change in the input state. The input must be active for at least 750 milliseconds in order to be recognized.

For descriptions and examples of how to provide open, and open/short circuit monitoring, and Class A or Class B wiring on EDIO inputs, refer to the Installation section of the EQP Instruction Manual, 95-8533. Refer to Appendix A for the different  $\lambda_{DU}$  values for open versus open and short circuit monitoring.

### EDIO Digital Output Channel

The EDIO output channel is normally de-energized and must employ line supervision to be safety rated.

For descriptions and examples of how to provide open, and open/short circuit monitoring, and Class A or Class B wiring on EDIO outputs, refer to the Installation section of the EQP Instruction Manual, 95-8533. Refer to Appendix A for the IDU value for open and open and short circuit monitoring.

### HSDM INPUT CHANNEL

A change in input state is only recognized if the new input state is held for a finite time interval to ensure that noise is not incorrectly interpreted as a change in the input state.

For descriptions and examples of how to provide open, and open/short circuit monitoring, and Class A or Class B wiring on HSDM inputs, refer to the HSDM Instruction Manual, 95-8782 for different IDU values for open versus open and short circuit monitoring.

### HSDM OUTPUT CHANNEL

The HSDM output channel is normally de-energized and must employ line supervision to be safety rated.

For descriptions and examples of how to provide open, and open/short circuit monitoring, and Class A or Class B wiring on HSDM outputs, refer to the HSDM Instruction Manual, 95-8782 for the lamda DU values for open and open and short circuit monitoring.

### UD10-DCU WITH AND WITHOUT CGS

The FlexVu® Model UD10 DCU Emulator (UD10-DCU) is designed for applications that require a gas detector with digital readout of detected gas levels. Its LON interface board makes the UD10-DCU compatible with Eagle Quantum Premier systems by digitizing the 4-20 mA analog signal from the attached sensor/transmitter and transmitting the value as a process variable over the LON to the EQP controller.

For descriptions regarding use of this display, refer to the UD10-DCU Instruction Manual, 95-8656.

### EQ3760ASM

The SIL EQ3760 provides up to 100 channels of

configurable input and output devices, including SIL-rated modules and non-interfering modules as follows:

SIL-Rated Apollo Devices	Max. Alarm Response Time (Seconds)
Apollo Heat Detector, SIL2 (58000-400SIL)	10
Apollo Smoke, SIL2 Optical (58000-600SIL)	10
Apollo Multisensor, SIL2 (58000-700SIL)	10
Apollo Manual Call, Standard, Isolated, Non-waterproof, SIL2 (58100-908SIL)	3
Apollo I/O, Standard, SIL2 (55000-847SIL)	30

**Note 1:** Alarm response time is defined as the period of time from device state change to EQP output.

**Note 2:** The Automatic Integrity Check (AIC) must be enabled.

Non-Interfering Apollo Loop Devices:

- Refer to EQ3760ASM manual (95-8755), table 3, page 4 for non-interfering Apollo devices.

## POWER SUPPLIES

The power supply selected must provide over-voltage protection to the EQP System. The over-voltage protection must be set for a maximum of 33 Vdc.

The EQP Safety System is NFPA-72 certified for use with Det-Tronics EQP Power Supplies, power supply monitoring, and ground fault monitoring.

Redundant power supplies can be implemented by “pairing” supplies. This is not required for the certified safety integrity level, but will improve availability.

The EQPSL devices must be operated between 18 and 30 Vdc. A 10% overvoltage will not damage the devices.

## S<sup>3</sup> CONFIGURATION SOFTWARE

S<sup>3</sup> Software is an engineering tool for configuring parameters and writing control programs (known as Projects) that are downloaded to EQP Controllers. The creation of the Project is the responsibility of the user and must conform with the restrictions in this manual.

This section describes the features of S<sup>3</sup> Software applicable to the EQP Safety System. More general information regarding the operation and use of S<sup>3</sup> can be found in the S<sup>3</sup> manual (number 95-8560).

A summary of S<sup>3</sup> Software features specific to its use with EQP Safety Systems is given below.

- Only input data from safety approved field devices (X3301-SIL/Eclipse-SIL/EDIO-SIL/AIM-SIL LS2000-SIL/ASM/UD10-DCU with and without CGS) can be used as safety data in EQP Safety Logic.
- Safety-related inputs and outputs are colored red to distinguish them from non-safety related I/O.
- User function blocks that are suitable for safety-related data are colored red to distinguish them from functions that are not suitable for safety-related data.
- Floating point values are not safety rated and must not be used in the safety-related logic.
- Numeric calculations are not error checked for overflow or underflow and the results of such calculations are not defined. It is the user's responsibility to bound inputs so such a condition cannot happen.
- Change control logging and event recording are available within S<sup>3</sup> and EQP Safety Controllers.
- Operations over the Ethernet Interface Board are controllable through use of the S<sup>3</sup> Download/Write Enable parameter on the EQP Controller Editor screen.

While S<sup>3</sup> is acceptable for configuring a low demand SIL 2 EQP System, it shall not be part of the safety function.

## S<sup>3</sup> Password Protection

The user must define what measures are to be applied to protect against project changes. S<sup>3</sup> provides safeguards described in the following paragraphs.

Access to the S<sup>3</sup> software program is restricted by password protection. Passwords can be changed at any time by the user with the correct privileges. S<sup>3</sup> supports up to 62 unique user accounts, each capable of having a different password and access privileges. These user accounts are controlled by the S<sup>3</sup> system administrator.

## Configuring User Accounts

There are five parameters that are used to configure the users account.

### User Level

A user level between 0 and 65535 is used to determine what a user can do. Each command or button that a user can interact with in S<sup>3</sup> has a user level assigned to it. The higher the number,

the higher the “privileges” for that user. A user level of “0” would allow “browsing” only with no command capability.

### Configure System Enabled

When selected, this option allows the user access to the engineering and configuration aspects of the S3 software suite. This includes the ability to make, move, configure, and delete ports and the ability to create or modify points like fire detectors, gas detectors, analog transmitters, digital inputs, etc. attached to one or more of the available ports.

### Quit “Online” Operations Enabled

When selected, the user is able to quit online operations and return to the S3 main screen for access to the various engineering and maintenance utilities.

### Port Diagnostics Viewing Enabled

When selected, the user can access the port diagnostics screen while online. This screen allows the user to view details about the operation of all active communication ports, whether serial or ethernet. This would typically be used by a technician responsible for troubleshooting connectivity between the S<sup>3</sup> station and any attached systems.

### Restricted Access Enabled

This feature is intended to enable limited access of the EQP port configurations for viewing and documentation purposes.

User accounts can be created with only the “restricted access” check box selected, or combined with the other check boxes — configure system, quit online, and port diagnostics.

### S<sup>3</sup> Change Control Log

S<sup>3</sup> maintains a Configuration Log that records changes in the master project file. The log can be viewed from S<sup>3</sup>.

A record is made in the Configuration Log when:

- IO Modules are added, deleted, or moved
- Tags are added to, removed from, or moved within an IO Module
- IO configuration parameters are saved
- External node numbers are entered or modified

- Serial communications parameters are entered or modified
- A successful download is made to a controller
- A project is removed.

### S<sup>3</sup> Function Block Logic

The S<sup>3</sup> software allows users to customize application software with the use of function block logic. For SIL certified systems, SIL rated function blocks must be used to comply with the SIL-2 certification.

The SIL rated function blocks and associated input and output links are color coded red to help the user identify quickly if there are any non-compliant blocks. Refer to Appendix B for a list of available function blocks.

Clearly separate safety-related function logic from non-interfering logic. Place all safety functions on their own logic pages, and place all non-interfering functions on their own logic pages.

#### NOTE

*It is the user's responsibility to test, verify and validate all safety related custom logic for conformance to the code.*

### SYSTEM SECURITY

A threat analysis for the EQP System was conducted identifying issues that the customer needs to address to maintain information assurance.

Ethernet access to the EQP system enables outside users to access the Safety Instrumented System through a widely available physical layer. Allowing external access to S<sup>3</sup> via open loop systems such as the Internet jeopardizes the Safety Integrity Level of a safety instrumented system using EQP.

The customer is responsible for protecting the EQP system from unauthorized access. Unauthorized access could result in modifications to system parameters, especially during project downloads, **oi** fire tests, and inhibit commands. Adverse events that could occur as a result of unauthorized access include:

- Inhibiting alarms during hazardous conditions
- False alarms

- Tampering with logs
- Collecting data on system performance.

The security features of EQP provide a basic layer of protection against unauthorized access.

Two actions are required to manage the security state:

1. The S<sup>3</sup> Download/Write Enable parameter must be left at DISABLED.

**NOTE**

*If the Write Enable parameter is set for*



Location of ENTER Button on EQP Controller Faceplate

*ENABLED, the EQP system can be safe from malware only if it is installed on a network that is physically separate from any other networks.*

2. The ENTER button on the Controller faceplate must be depressed to allow downloads to the controller. Once depressed, the controller will enable external access for five minutes, thereby allowing parameter modifications to be made. Once a download has begun, it will continue until completed.

**Access Control**

The previous section explained how S<sup>3</sup> provides the ability to control access to the EQP system by configuring user accounts. It is the responsibility of the customer to ensure proper access control of the Safety Instrumented System. The restricted access enabled check box allows S<sup>3</sup> to be used with the SIL-capable EQP when checked. This discretionary access control (DAC) limits access between users and the SIS based on identity of the user and, potentially, the groups in which the user belongs.

The following identity-based access must be considered when configuring user accounts (see table).

Proof Test Name	Commissioning	Frequency per Year
EDIO Input Channel Proof Test	Yes	1
EDIO Output Channel Proof Test	Yes	1
AIM Input Channel Proof Test	Yes	1
X3301/2 Visual Field Inspection Proof Test	Yes	As needed, depending on level and type of contaminants present
X3301/2 Mag oi Proof Test	Yes	1
PIRECL Visual Field Inspection Proof Test	Yes	As needed, depending on level and type of contaminants present
PIRECL Gas Response Proof Test	Yes	1
LS2000 Gas Response Proof Test	Yes	1
EQP User Logic Verification	Yes	—
ASM Apollo Loops Proof Test	Yes	1
UD10-DCU (with and without CGS)	Yes	As needed, depending on level and type of contaminants present
High Speed Deluge Module	Yes	1

	Configuration	Inhibit	Diagnostics	Silence
Administrator	X	X	X	X
Maintainer		X	X	X
Operator				X

## PROOF TESTING

After installation and start-up have been completed, Proof Tests must be performed for the Det-Tronics EQP Safety System.

Personnel performing Proof Test procedures must be competent to perform the task. All Proof Test results must be recorded, analyzed, and any errors in the safety functionality must be corrected. The Proof Tests must be performed at a frequency as shown in the table on page 11.

### **⚠ WARNING**

*To prevent undesired actuation of alarm equipment, systems or signaling devices, be sure to secure these devices prior to performing the test.*

### **⚠ WARNING**

*Failure to perform the specified testing and inspection may lower or void the SIL rating for the product or system.*

## EDIO INPUT CHANNEL PROOF TEST

Tools Required: None

Initiate the input channel via the connected contact closure device. Verify correct operation at the EDIO by the local channel LED turning red. If the input is classified as a flame or gas device, verify correct alarm display at the EQP controller.

## EDIO OUTPUT CHANNEL PROOF TEST

Tools Required: None

Initiate the EDIO output channel by the user logic or activate the associated input devices (EDIO input, flame detectors, gas detectors, etc.). Verify correct operation at the EDIO by the local channel LED turning red. Verify that the end device connected to the EDIO channel is activated.

## HSDM PROOF TEST

Tools Required: None

Initiate the HSDM output channel by the user logic or activate the associated input devices (HSDM input, flame detectors, initiating devices, etc.). Verify correct operation at the HSDM by the local channel LED turning red. Verify that the end device connected to the HSDM channel is activated within the required response time.

## AIM INPUT CHANNEL PROOF TEST

Tools Required: None

1. Bypass the safety function and take appropriate action to avoid a false trip.
2. Retrieve any diagnostics via the EQP controller and take appropriate action.
3. Using the connected 4-20 mA device, input a high alarm current level to each configured channel and verify correct operation at the AIM by the local channel LED turning red on that channel and no others. Verify that the correct alarm is displayed at the EQP controller for that channel and no others.
4. Using the connected 4-20 mA device, input an under-current level to each configured channel and verify correct operation at the AIM by the local channel LED turning amber on that channel and no others. Verify that an under-current condition is correctly displayed at the EQP controller for that channel and no others.
5. Remove the bypass and otherwise restore normal operation.

## ASM APOLLO LOOP PROOF TEST

Tools Required: None

1. Bypass the safety function and take appropriate action to avoid a false trip.
2. Retrieve any diagnostics via the EQP controller and take appropriate action.
3. Using the connected Apollo devices, initiate alarm to each device independently and verify correct operation at the ASM by the local channel LED turning red. Verify that the correct alarm is displayed at the EQP controller for each device.
4. Remove the bypass and otherwise restore normal operation.

### **X3301/2 VISUAL FIELD INSPECTION PROOF TEST**

Visual inspection of all Safety-Certified X3301/2 Multispectrum IR Flame Detectors shall be conducted as needed to confirm that there are no obstructions in the optical field of view. Corrective action will include removal of such impediments should they exist.

### **X3301/2 MAGNETIC **o**<sub>i</sub> PROOF TEST**

Tools Required: Magnetic **o**<sub>i</sub> test tool (p/n 102740-002)

All flame detectors must be performance tested using the Magnetic **o**<sub>i</sub> Procedure and inspected to ensure that they are capable of providing expected performance and protection. Note that the Magnetic **o**<sub>i</sub> Procedure and Manual **o**<sub>i</sub> Tests are not interference free. During these tests the unit is not performing normal flame detection functions. Model X3301/2 provides an onboard status LED, which indicates green when internal operational parameters are normal. Upon successful completion of the Magnetic **o**<sub>i</sub> test, the LED changes to red and an alarm status is sent to the EQP controller. In the event the proof test is unsuccessful, the LED remains green and the controller does not indicate a fire alarm.

### **LS2000 OPTICAL TEST FILM METHOD (RECOMMENDED)**

Tools Required: LS2000 System Test Film (p/n 012673-001)

The test film provides a means of testing the operation of the Model LS2000 IR Gas Detector. When the test film is placed in the beam of the line-of-sight detector, the detector output will rise to a specific value.

The LS2000 test film packet consists of five separate test film cards. A single card can be used, or the cards can be "stacked" to simulate up to five different gas concentrations. Light shining through one card corresponds to the lowest LFL-m for a particular gas, while light shining through all five cards corresponds to the highest LFL-m reading for a particular gas. Table 7 of the LS2000 Instruction Manual shows the response of the three standard LS2000 gas type settings to each of the five test film values.

Proper operation can be confirmed by bypassing all system alarms, then placing the optical test film into the light beam and checking for

the appropriate 4-20 mA output level or relay actuation.

Alarm conditions, if present, should clear when the test film is removed from the beam (in non-latching mode, see LS2000 instruction manual for details).

The test film is typically used to verify the factory calibration of the LS2000. The test film is not intended for routine use. It does, however, demonstrate in a very direct way the response of the detector to hydrocarbons along with the resulting control action. This is particularly useful when required by regulatory authorities.

For complete information regarding proper use of the test film and testing of the LS2000 detector, refer to the LS2000 manual number 95-8714.

### **PIRECL VISUAL FIELD INSPECTION PROOF TEST**

Tools Required: None

Visual inspection of all Safety-Certified PIRECL Gas Detectors shall be conducted weekly to confirm that no external blockage of gas/vapor path into the sensing chamber exists, e.g. debris, trash, snow, mud, external equipment, etc. Corrective action shall include removal of such impediments should they exist. All gas detectors must be inspected to ensure that they are capable of providing expected performance and protection. Model PIRECL provides an onboard status LED that indicates green upon inspection when internal operational parameters are normal. Abnormal operating parameters are indicated by yellow (Fault) or red (Alarm).

### **PIRECL GAS RESPONSE PROOF TEST**

Tools Required: Calibration Gas Kit (p/n 006468-001)

This proof test, commonly referred to as a "gas bump test", requires application of high accuracy compressed calibration gas to the detector while in NORMAL operational mode and inspecting the signal output level to ensure that the signal output is accurately indicative of the applied test gas concentration.

When test gas is flowing into the detector, inspection of proper gas response can be made by reading the output displayed on the controller. Criteria for inspection pass is a response signal within  $\pm 3\%$  of applied gas concentration (50%

LEL test concentration applied). If response test is not within acceptable limits, then a Full Calibration procedure must be performed and Gas Response Proof Test re-performed.

### **LS2000 GAS RESPONSE PROOF TEST**

All normal installation, start-up, and field calibration recommendations as documented in the STARTUP section of the LS2000 instruction manual are applicable to the Safety Certified LS2000 gas detector.

### **UD10-DCU RESPONSE PROOF TEST**

Tools Required: Compressed Calibration Gas Kit available from Det-Tronics, or other device stimulation method

1. Bypass the safety function and take appropriate action to avoid a false trip.
2. Retrieve any diagnostics via the EQP controller and take appropriate action.
3. The Response Proof Test must be performed while the UD10-DCU and attached device are in NORMAL operation and requires application of sufficient stimulation to put the device into alarm state.
4. The user must then inspect the signal output level to ensure that the signal output is accurately indicative of the applied condition.
5. Remove the bypass and otherwise restore normal operation.

### **EQP USER LOGIC VERIFICATION**

All user Safety Logic needs to be fully tested and verified using the safety inputs and outputs. This is a commissioning activity, however, if logic is modified in the future proof testing must be repeated. If the controller is replaced, project information must be loaded into the new controller and verified. The CRC of project related data is calculated and saved by the controller after each project download. The project CRC can be viewed on the controller's display under User Logic/General Info/Logic CRC. The project CRC should be recorded and saved when proof testing is completed. The project CRC from the controller must be compared to the saved value when a controller is replaced to avoid complete proof testing of the system.

## **INSTALLATION**

General installation instructions are found in the instruction manual for the EQP system, form number 95-8533.

Like other Det-Tronics EQP products, the ingress protection rating of the EQP Safety Controller, EDIO, and AIM is IP20. It will be necessary to mount the EQP Safety Controller, EDIO, and AIM in a suitable enclosure to provide mechanical and ingress protection appropriate to the particular application. Access can be restricted by mounting the EQP controller in a locked enclosure.

### **COMMISSIONING PERSONNEL**

The Safety Certified EQP System can be commissioned by any qualified person with knowledge of EQP System instruments and the configuration device being used.

## **SUITABLE APPLICATIONS**

The EQP Safety System can be used to provide safety functions up to Safety Integrity Level 2 (SIL 2). It can be used in low demand applications only.

Typical low demand applications are:

- Fire and Gas protection systems, which monitor for the presence of fire or a release of gas, and annunciate/release when demanded upon.

In this case, the process safety time must be greater than the response time of the EQP Safety System.

## **GENERAL APPLICATION REQUIREMENTS**

### **System Application Restrictions**

The following application level restrictions have been assumed:

- The EQP system is only used for safety applications that are low demand according to IEC 61508 definitions.
- Only Det-Tronics EQP system devices may be connected to EQPSL network (closed network).
- Physical EQPSL network topology is limited to a single loop.

- Indication of degraded conditions through opening of the EQP controller's fault relay must be investigated and the conditions corrected within time period determined by SIF verification calculations for the particular application.
- Periodic proof testing of trip signals through EQPSL network at least once per 5 years (1 year recommended).
- Periodic proof test of input sensors at least once per 3 years (1 year recommended).
- Product life limited to 20 years.
- The EQP System is operated within the environmental conditions described in the Specifications section of EQP Instruction Manual (number 95-8533).

### Application Standards

The EQP Safety System is certified to meet the requirements of a number of application standards that are listed in this Safety Manual and on the *exida*® certificate. Users must ensure that they comply with all the requirements of the standard, not just those that apply to the EQP Safety System.

### Operator Interface

The EQP Safety System may be connected to an operator interface, matrix panels, mimic panels and switches.

These interfaces allow the operator to monitor the operation of the system and diagnose system faults.

The EQP Safety System will allow detected faults (from line supervision monitoring, internal diagnostics etc.) to be displayed or indicated.

### S<sup>3</sup> Safety System Software

Programming, downloading, safety-related parameters, and programs and switching between operating states is carried out via an engineering workstation using S<sup>3</sup> Software.

Access to the programming interface shall only be permitted for authorized and suitably qualified personnel. Access must be restricted by the use of passwords (and the options to do this are provided for within S<sup>3</sup> Software) and/or some other forms of restricting access.

The programming interface may be used as the operator interface, but use of the programming interface must be restricted to authorized and qualified personnel.

Instructions for using S<sup>3</sup> and typical application examples are provided in the S<sup>3</sup> Instruction Manual (number 95-8560).

### Hardware Fault Tolerance, Safe Failure Fraction and Sub-System Type

The EQP Safety System is a Type B system, with a hardware fault tolerance of 0 and a safe failure fraction of >90%. It is, therefore, suitable for use in safety functions requiring a safety integrity level of 2..

### Calculating PFD for Low Demand Applications

This section gives a basic introduction to calculating the average probability of failure on demand (PFDavg) for a safety function incorporating the EQP Safety System.

For the purpose of this example, the following assumptions have been made:

- All components are certified as suitable for use in SIL 2 safety-related applications.
- All elements are used in 1oo1 arrangements.
- Any Mean Time To Restore (MTTR) less than 48 hours is negligible.
- The approximation  $PFD_{avg} = 1/2 T_1 \lambda_{DU}$  is valid for the proof test interval considered.

PFDavg for a particular safety function is the sum of the probabilities of the average failure on demand of each element of the system, taking into account the proof test interval of each element.

Table 1 provides the low demand EQP SIL 2 Safety Function model and recommendations for complex modeling.

PFDavg for each element is calculated according to the equation above, where  $\lambda_{DU}$  is the undetected dangerous failure rate per 10<sup>9</sup> hours and T1 is the proof test interval. (In this example, T1 is chosen as 1 year (8760 hours) for all components of the safety function).

The value of PFDavg for the system is the sum of PFDavg for the individual elements.

**NOTE**

The EQP system is an energize to trip system. The power supply to the output device should be monitored and annunciator when lost. This is counted as (DD) fault. If the power supply is not monitored, it must be counted as a Dangerous Undetected (DU) fault.

**Example 1 (Figure 3A)**

Fire input from an X3301 and output to an EDIO.

$$PFD_{avg} = 0.58 \times 10^{-3} + (0.38 \times 10^{-3} + 0.1 \times 10^{-3}) + 0.1 \times 10^{-3} + \text{valve \& supply} = 1.16 \times 10^{-3} + \text{valve \& supply}$$

**Example 2 (Figure 3B)**

Gas alarm from a PIRECL and output to an EDIO.

$$PFD_{avg} = 0.58 \times 10^{-3} + (0.38 \times 10^{-3} + 0.1 \times 10^{-3}) + 0.1 \times 10^{-3} + \text{valve \& supply} = 1.16 \times 10^{-3} + \text{valve \& supply}$$

**Example 3 (Figure 3C)**

Input from an EDIO and output to the same EDIO.

$$PFD_{avg} = 0.003 \times 10^{-3} + (0.38 \times 10^{-3} + 0.1 \times 10^{-3}) + 0.1 \times 10^{-3} + \text{valve \& supply} = 0.58 \times 10^{-3} + \text{valve \& supply}$$


Using the table given in the standard, this value would be suitable for a low demand SIL 2 safety function. Other conditions (hardware fault tolerance and safe failure fraction) also allow its use in a SIL 2 application.

See IEC 61508-6 for a more comprehensive guide to the calculation of PFDavg.

Table 1— EQP SIL 2 Safety Function Model - Example

Safety Function INPUT	Safety Function OUTPUT	SFF	Total Failure Rate	DU (Failure to Trip)	SU (False Trip)	DD (Detected Fault)
X3301 Fire Input	EDIO OUTPUT (OPEN MONITORING)	96.6%	7,070 FIT	242 FIT	226 FIT	2,980 FIT
EDIO Fire Input (OPEN & SHORT MONITORING)	EDIO OUTPUT (OPEN MONITORING)	96.9%	3,580 FIT	110 FIT	130 FIT	2,020 FIT
PIRECL Gas Input	EDIO OUTPUT (OPEN MONITORING)	96.2%	6,420 FIT	242 FIT	316 FIT	3,920 FIT
EDIO Gas Input (OPEN & SHORT MONITORING)	EDIO OUTPUT (OPEN MONITORING)	96.9%	3,580 FIT	110 FIT	130 FIT	2,020 FIT

NOTES: The table includes consideration to a 246 node system with 6 Network Extenders, 14 Physical Layer Repeaters, maximum cable distance, and a 1-year Proof Test Interval (NFPA 72 requirement) with usage of less than 65% of the SIL 2 budget.  
One EDIO provides both the input channel and the output channel.  
For complex modeling of the EQP System, reference the *exida*® tool at [www.exida.com](http://www.exida.com).



λ.DU IS FAILURE RATE PER 10<sup>9</sup> HOURS, T<sub>F</sub> OF 1 YEAR = 8760 HOURS, PFD<sub>avg</sub> IS THE PROBABILITY OF FAILURE ON DEMAND.


$$PFD_{avg} = \sum (1/2 \cdot T_1 \cdot \lambda_{DU})$$

\*Includes Worst Case Safety Communication  
(λ.DU = 22.8, PFDavg = 0.1 x 10<sup>-3</sup>)

\*\*Single Output Configuration, Monitored for Opens

\*\*\*See note in Calculating PFD for Low Demand Applications

Figure 3A—X3301 Input in a Typical Low Demand Application



λ.DU IS FAILURE RATE PER 10<sup>9</sup> HOURS, T<sub>F</sub> OF 1 YEAR = 8760 HOURS, PFD<sub>avg</sub> IS THE PROBABILITY OF FAILURE ON DEMAND.


$$PFD_{avg} = \sum (1/2 \cdot T_1 \cdot \lambda_{DU})$$

\*Includes Worst Case Safety Communication  
(λ.DU = 22.8, PFDavg = 0.1 x 10<sup>-3</sup>)

\*\*Single Output Configuration, Monitored for Opens

\*\*\*See note in Calculating PFD for Low Demand Applications

Figure 3B—PIRECL Input in a Typical Low Demand Application



λ.DU IS FAILURE RATE PER 10<sup>9</sup> HOURS, T<sub>F</sub> OF 1 YEAR = 8760 HOURS, PFD<sub>avg</sub> IS THE PROBABILITY OF FAILURE ON DEMAND.

$$PFD_{avg} = \sum (1/2 \cdot T_1 \cdot \lambda_{DU})$$

\* Single Input Configuration with Open & Short Monitoring.  
λ.DU for Components Common to both Inputs  
and Outputs Contained in EDIO and Output  
Calculation

\*\* Includes Worst Case Safety Communication  
(λ.DU = 22.8, PFDavg = 0.1 x 10<sup>-3</sup>)

\*\*\*Single Output Configuration, Monitored for Opens

\*\*\*\*See note in Calculating PFD for Low Demand Applications

Figure 3C—EDIO Input in a Typical Low Demand Application

## System Response Time

The EQP Safety System will have a typical response time of less than 1 second, to which must be added the response time of the final elements to give the total response time.

The worst case theoretical response time of the EQP Safety System, the time taken from an input transition being detected to an output being asserted, is estimated by the following:

- Detection at field device to the Controller over EQPSL network
  - Small system <100 field devices < 3.2 seconds (user logic constrained to 0.5 seconds)
  - Large system >100 field devices < 9.1 seconds (user logic constrained to 1.5 seconds).
- Worst case response times assume user logic execution time is constrained to
  - Small system < 0.5 seconds
  - Large system < 1.5 seconds.
- Worst case Controller to EDIO output < 6.3 seconds.
- Worst case response times assume a high level of lost messages due to internal or external influences, and three subsequent retries.

### NOTE

*The worst case theoretical response time, as required by IEC 61508, will only occur once per 1,000,000 trips. It must occur during the worst case degraded communication conditions possible without generating a communication fault.*

### NOTE

*The process safety time must be compared with the response time of the entire safety function. In addition to the response time of the EQP Safety System, the response time of the input sensors and output actuators must be included.*

## Product Repair

The EQP Controller and Field Devices are not field-repairable and any internal device repairs must be conducted at the factory. No firmware changes are permitted or authorized. All failures indicated by internal diagnostics or Proof Tests that cannot be resolved through the troubleshooting and maintenance procedures described in the manual must be reported to the manufacturer. Refer to the DEVICE REPAIR AND RETURN section of the EQP system instruction manual, number 95-8533.

## Spare Parts

Refer to the REPLACEMENT PARTS section of the instruction manual. Safety certification is based on a sufficient number of spares to achieve a 24 hour mean time to repair.

## Applicable Standards

- IEC 61508:2010. "Functional Safety of Electrical/Electronic/Programmable Electronic Safety-related Systems".
- IEC 61511:2003. "Functional Safety - Safety Instrumented Systems for the Process Sector".

## Product Certifications



FM, CSA, ATEX, IECEx, CE, exida, and others.

FMEDA Report available.

For complete information regarding performance, installation, operation, maintenance and specifications of the Eagle Quantum Premier system, refer to instruction manual 95-8533.

# APPENDIX A

## SUMMARY OF SAFETY RELATED DATA

### CERTIFICATION AND FAILURE RATE DATA

All Safety-Certified EQP devices are certified compliant to:

- IEC 61508: 2000 Parts 1-7
- Random Integrity: Type B Element
- Systematic Integrity: SIL 2 Capable
- HFT: 0

Low Demand Mode

PFDavg should be calculated for any safety instrumented function using the EQP System.  
(Refer to tables and / or FMEA report for necessary information, including DU rate).

Safety Accuracy: Specified per device

Safety Response Time: See 'System Response Time' section

IEC 61508 Failure Rates

Certified for use up to	SIL 2	Configuration	1oo1D
Architecture Type	B	Hardware Fault Tolerance	0
Safe Failure Fraction	> 90%		
Failure Rate Data			
Part	Model	$\lambda_{DU}$ (dangerous undetected failure rate per 10 <sup>9</sup> hours)	SFF %
EQP Safety Controller	EQ3xxx	74	98
EDIO Safety Module - Configured as Input*	EQ3730EDIO	Common = 59 Input Monitored for Opens = 23 Input Monitored for Opens & Shorts = 23	94 94.8 94.8
EDIO Safety Module - Configured as Output*	EQ3730EDIO	Output Monitored = 53	94.7
AIM Safety Module	EQ3710AIM	Common = 92 Per Input Channel = 26	90.7 91.5
Addressable Smoke Module	EQ3760ASM	56	95.9
X3301/2 IR Flame Detector	X3301	55	96.7
Eclipse IR Gas Detector	Model PIRECL	147	95
Open Path IR Gas Detector	LS2000	59.4	96.7
EQP Safety Communications		22.8	N/A
UD10-DCU	UD10-DCU	80	N/A
UD10-DCU with CGS	UD10-DCU (CGS)	88	N/A
High Speed Deluge Module	EQ3780HSDM	385	96.7

\* “Common” are components common to both inputs and outputs. For  $\lambda_{DU}$  calculation:

Example 1: Input and output on same EDIO

$$\lambda_{DU} = \text{Common} + \text{Input} + \text{Output}$$

$$\lambda_{DU} = 59 + 23 + 23 = 105$$

Example 2: Input and output on different EDIOs

$$\lambda_{DU} = \lambda_{DU} \text{ EDIO \#1} + \lambda_{DU} \text{ EDIO \#2}$$

$$= (\text{Common} + \text{Input}) + (\text{Common} + \text{Output})$$

$$= (59 + 23) + (59 + 53) = 194$$

Product Life EQ3xxx (Controller): 10-25 years, based on manufacturer data.

Product Life EQ3730EDIO: 6-29 years, based on manufacturer data.

Product Life EQ3710AIM: 6-29 years, based on manufacturer data.

Product Life EQ3760ASM: 6-20 years, based on manufacturer data.

Product Life X3301: 12-27 years, based on manufacturer data.

Product Life PIRECL: 5-40 years, based on manufacturer data.

Product Life LS2000: 10 years, based on manufacturer data.

Product Life: UD10-DCU: 10 years, based on manufacturer data.

All failure rate data for SIL verification is in the FMEDA report, which is available upon request.

## TERMS AND DEFINITIONS

DD	Dangerous Detected
DU	Dangerous Undetected
EQP	Eagle Quantum Premier System
EQPSL/SLC	Eagle Quantum Premier Safety Loop / Signaling Line Circuit
FMEDA	Failure Mode Effects and Diagnostics Analysis
HART	Highway Addressable Remote Transducer
HFT	Hardware Fault Tolerance
PFD	Probability of Failure on Demand (Probability of Dangerous Failure)
PFDavg	Average Probability of Failure on Demand
SD	Safe Detected
SFF	Safe Failure Fraction
SIF	Safety Instrumented Function
SIL	Safety Integrity Level
SIS	Safety Instrumented System
SU <sub>1,1</sub>	Safe Undetected

## APPENDIX B

### EQP CONTROLLER LOGIC GATE TABLE USER-DOCUMENTATION

The "SIL" column indicates if the gate is suitable for use with alarm processing with a 61508 approved system. Gates that utilize stored values which are not duplicated, or that depend on the floating-point or string libraries are not safety rated. For detailed information about a gate, refer to the help file for that gate in the S<sup>3</sup> EQP logic window.

Gate Name	Description	SIL
ABS	Absolute Value. The values can be integer, double or float. The result will be of the same type as the input value; e.g. $-23 = 23$	Yes for all but floating-point values
ACCALM	Access Alarm. This function is used to provide an interface to the Controller's alarm list. This can be used to read alarm information from the Controller's alarm list.	No
ADD	Addition. The values can be Boolean, integer, double or float. All items must be of the same type. ADD reads all the values, performs an ADD function and writes the result.	Yes for all but floating-point values
ALMTGR	Add an Alarm to the Alarm List. This function is used to add an alarm to the Controller's alarm list. This can be used to trigger and log and display alarms that are initiated by user logic.	No
AND	AND. AND reads all the values, performs a bitwise AND function and writes the result.	Yes
ANDW	AND Word. The values can be integer or double. All values must be of the same type and the result will be of the same type. All of the bits of the word are operated on.	Yes
AVG	Average. The input values can be integer, double or float. All values must be of the same type and the result will be of the same type. Average is the value obtained by dividing the sum of the value by the number of values. $(8.0 + 7.0 + 8.0) / 3 = 7.6$ .	Yes for all but floating-point values
BINT	Boolean to Integer. The input is a Boolean. If the input is False the output will be a zero and if the input is True the output will be a one.	Yes
BTW	Between. The input values can be integer, double or float. All items must be of the same type. There are three input items. Two are the comparison values and the third is the compare item. If the compare item is equal to or between the comparison values, a Boolean True is output, if not a Boolean False is output; e.g. if the $\leq$ input is 100 and the IN input is 50 and the $\geq$ input is 0 then the output would be True.	Yes for all but floating-point values
BTWT	Between Time Compare. There are three input time/date items. Two are the comparison values and the third is the compare item. If the compare item is equal to or between the comparison values, a Boolean True is output, if not a Boolean False is output; e.g. if the $\leq$ input is 15:00:00 and the IN input is 12:00:00 and the $\geq$ input is 06:00:00 then the output would be True.	No
CEIL	Ceiling. This function performs a round up. The input is a float. The result will be a double; e.g. $-2.8 = -2$ , $2.8 = 3$ , $-1 = -1$	No

CTD	<p>Down Counter. There are three inputs. They are "count down (CD)" a Boolean, the "Load (LD)" a Boolean, and the "Preset Value (PV)" a double.</p> <p>When the LD input is False, the counter counts down. One count for each CD transition from False to True.</p> <p>The output is True if the current value is less than or equal to zero. The counter stops counting when the current value reaches -2,147,483,648.</p> <p>When the LD is True, the PV is loaded into the current value to initialize the counter.</p>	No
CTD-SIL	<p>SIL Down Counter. The SIL Down Counter operates the same as the standard CTD, but provides additional error checking in the Controller against random memory error.</p>	Yes
CTU	<p>Up Counter. There are three inputs. The "count up (CU)" a Boolean, the "Reset (R)" a Boolean, and the "Preset Value (PV)" a double.</p> <p>When the R input is False, the counter counts up. One count for each CU transition from False to True.</p> <p>The output is True if the current value is greater than or equal to the PV.</p> <p>The counter stops counting when the current value reaches 2,147,483,647.</p> <p>When R is True the current value is set to 0.</p>	No
CTU-SIL	<p>SIL Up Counter. The SIL Up Counter operates the same as the standard CTU, but has additional error checking in the Controller against random memory error.</p>	Yes
CTUD	<p>Up/Down Counter. This has five inputs. The "count up (CU)" a Boolean, the "count Down (CD)" a Boolean, the "Reset (R)" a Boolean, the "Load (LD)" a Boolean and the "Preset Value(PV)" a double.</p> <p>When the LD and R inputs both are False, the counter counts.</p> <p>One count up for each CU transition from False to True.</p> <p>One count down for each CD transition from False to True.</p> <p>If both CU &amp; CD transition, the counter will count up.</p> <p>If the current value is greater than or equal to the PV, QU output is True.</p> <p>If the current value is less than or equal to zero, QD output is True.</p> <p>The counter stops counting when the current value reaches 2,147,483,647 or -2,147,483,648.</p> <p>When the R is True the current value is set to zero.</p> <p>When the LD is True the PV is loaded into the current value to initialize the counter.</p>	No
CTUD-SIL	<p>SIL Up/Down Counter. The SIL Up Counter operates the same as the standard CTU, but has additional error checking in the Controller against random memory error.</p>	Yes
DBLFLT	<p>Double to Float. The input double is converted to a float.</p>	No
DBLINT	<p>Double to Integer. The input double is converted to an integer.</p>	Yes
DBLSTR	<p>Double to String. When the enable input is True, the 32-bit double input value is converted to a string.</p>	No
DIV	<p>Divide. The input values can be integer, double or float. The inputs must be of the same type. The output will be of the same type as the inputs.</p>	Yes for all but floating-point values
ET	<p>Equal To. The input values can be integer, double or float. The inputs must be of the same type. The output is a Boolean. NOTE: When floats are used in a comparison for Equal (=), the comparison will be true if the values are within 0.01 of each other.</p>	Yes for all but floating-point values

EVTGR	Add an Event to the Controller Alarm List. This function is used to add an event to the Controller's alarm list. This can be used to trigger, log and display events that are initiated by user logic.	No
FLR	Floor. This function performs a round down. The input value is a float. The result will be a double; e.g. $-2.8 = -3$ , $2.8 = 2$ , $-1 = -1$	No
FLTSTR	Float to String. When the enable input is True, the floating-point input value is converted to a string. The precision input determines the number of digits to the right of the decimal point. (0 - 6)	No
FRAC	Fraction. The output will be the fractional part of the input. The input value is a float. The result will be a float; e.g. $123.456 = 0.456$ .	No
GT	Greater Than. The input values can be integer, double or float and must be the same type. The output is a Boolean. ( $X > Y$ )	Yes for all but floating-point values
GE	Greater Than or Equal To. The Input values can be integer, double or float and must be the same type. The result is a Boolean. ( $X \geq Y$ ).	Yes for all but floating-point values
IF	IF. The values at the input connection "True" can be Boolean, integer, double, string or float. If the Selector input is True, the value at the "True" connection is passed to the output. If the Selector Input is False the output will be set to the value determined at last scan when the Selector was True. The IF function is a way to preserve a value after the Boolean input goes False.	No
INPUT	Input. The Input can be any value. The input function is used to select an input that will be directed to logic.	Yes for all but floating-point and string values
INTBOL	Integer to Boolean. If the input is equal to zero, the output will be False. If the input is not equal to zero, the output will be True.	Yes
INTDBL	Integer to Double. The input integer is converted to a double.	Yes
INTFLT	Integer to Float. The Input integer is converted to a float. The result will be a float.	No
INTSTR	Integer to String. When the enable input is True, the 16-bit integer input value is converted to a string.	No
LMT	Limit. The values can be integer, double or float. All inputs must be of the same type. The output will be of the same type as the inputs. The input is compared against the high limit. If the input is greater than the high limit, the output will be the high limit value. If the input is less than the high limit, the input is compared against the low limit. If the input is less than the low limit, the output is the low limit value. Otherwise the output is the value of the input.	Yes for all but floating-point values
LT	Less Than. The values can be integer, double or float. The result is a Boolean.	Yes for all but floating-point values
LE	Less Than or Equal To. The values can be integer, double or float. The result is a Boolean.	Yes for all but floating-point values
MAX	Maximum Select. The values can be integer, double or float. The input with the highest value will be passed to the output. The result will be of the same type as the inputs.	Yes for all but floating-point values

MEDIAN	Median. The input values can be integer, double or float. All values must be of the same type and the result will be of the same type. Median is the value midway between the values. Definition: a) designating the middle number in a series containing an odd number of items; e.g. 7 in the series 1, 4, 7, 16, 43; b) designating the middle number midway between the two middle numbers in a series containing an even number of items; e.g. 10 in the series 3, 4, 8, 12, 46, 72.	Yes for all but floating-point values
MIN	Minimum select. The input values can be integer, double or float. All inputs must be of the same type. The input with the lowest value will be passed to the output. The result will be of the same type as the inputs.	Yes for all but floating-point values
MOD	Modulo. The input values can be integer or double. The result is the same type as the inputs. The mod operator returns the remainder obtained by dividing its operands. In other words: $9 \text{ mod } 4$ is 1.	Yes
MBREAD	MODBUS Read. This function block performs an asynchronous MODBUS read operation.	No
MBWRT	MODBUS Write. This function block performs an asynchronous MODBUS write operation.	No
MOFN	M of N. All of the Boolean inputs are examined for a True condition. The result is compared against the Preset (PR). The output ">" is True if the count is greater than the PR. The output "=" is True if the count is equal to the PR. The output "<" is True if the count is less than the PR.	Yes
MOSP	Multiple One Shot Pulse. The inputs are Boolean. The output is a Boolean. Each input has a one-shot pulse function. The output is the "OR" of all of the inputs after the result of each one-shot pulse function.	No
MUL	Multiply. The input values can be integer, double or float. The inputs must be of the same type. The result type is the same as the inputs.	Yes for all but floating-point values
MUX	Multiplex. The input values can be Boolean, integer, double, string or float. All input values must be the same type. The output is the item indexed by the selector input. The output will be the same type as the inputs.	Yes for all but floating-point and string values
NBITS	Number of Bits. The output will be the sum of all the binary inputs.	Yes
NE	Not Equal To. The values can be integer, double or float. The result is a Boolean.	Yes for all but floating-point values
NOT	NOT. The input values can be Boolean, integer or double. The output is the bitwise NOT of the input.	Yes
ODD	ODD. The input values can be integer or double. The function determines if the input value is odd. The result is a Boolean.	Yes
OR	OR. OR reads all the Boolean values, performs a bitwise OR function and writes the result. The result is a Boolean.	Yes
ORW	OR WORD. The input values can be integer or double. All values must be of the same type and the result will be of the same type. This function performs a logical OR of the inputs.	Yes
OSP	One shot pulse. The input is a Boolean. The output is a Boolean. When the input goes True, the output goes True for one program scan. The output will be False the next time the function block is executed, regardless of the input.	No
OSP-SIL	One shot pulse SIL. The input is a Boolean. The output is a Boolean. When the input goes True, the output goes True for one program scan. The output will be False the next time the function block is executed, regardless of the input.	Yes

OUTPUT	Output. The output can be any value. The output function is used to select an output that will be directed from logic.	Yes for all but floating-point and string values
PACK16	Bit Packing. This function performs a bitwise packing of the Boolean inputs into an integer.	Yes
PKDT	Pack Date/Time. This function performs packing of 6 integers into a Time/Date data type.	No
PULSER	Pulser. This function block creates periodic pulse of defined ON and OFF time-values. The ON and OFF time-values may be different.	
RND	Round. Half way values are rounded to the nearest even number (Bankers rounding). The input value is a float. The result will be a double; e.g. 5.5 rounds to 6, 6.5 rounds to 6, -5.5 rounds to -6, -6.5 rounds to -6.	No
RS	Reset/Set. If Reset input is set to True, then the output is False. If Set input is set to True and Reset input is False, then the output is True. If both are False, then there is no change in the output. This gate is Reset dominant bistable. If the Reset input is True, then the output is False, regardless of the Set input.	No
RS-SIL	SIL Reset/Set gate. The SIL Reset/Set gate operates the same as the standard RS, but provides duplicate storage for the persistent value.	Yes
RTM	Retentive Timer. This function block performs a Retentive On Timer function. It provides a delay of time PT from the rising edge of input IN.	No
RTM-SIL	SIL Retentive Timer. The SIL Retentive Timer operates the same as the standard Retentive Timer, but provides duplicate storage for the persistent values.	Yes
SCALE	Scale. The input values can be integer, double or float. All the values must be of the same type. The output will be of the same type. The first value is the input. The second value is the low range for the input. The third value is the high range for the input. The fourth value is the low range for the output and the fifth value is the high range for the output.	No
SEL	Selector. The True and False input values can be Boolean, integer, double, string or float. They must be of the same type and the output will be of this type. The selector input value is a Boolean. If the selector is False, then the value at the False connection is passed to the output. If the selector is True, then the value at the True connection is passed to the output.	Yes for all but floating-point and string values
SQR	Square. The input value is a float. The result will be a float.	No
SQRT	Square Root. The input value is a float. The result will be a float.	No
SR	Set/Reset. This function block performs a Set-Reset function. If the Set input is set to True, then the output is True. If the Reset input is set to True and Set input is False, then the output is False. This gate is the Set dominant bistable. If the Set input is True, then the output is True, regardless of the Reset input.	No
SR-SIL	SIL Set/Reset. The SIL Set/Reset gate operates the same as the standard Set/Reset gate, but provides duplicate storage for the persistent value.	Yes
STRAPD	String Append. When the enable input is True, source string 2 is appended to the end of source string 1 and placed in the destination string.	No
STRCPY	String copy. When the enable input is True, the source string is copied to the destination string.	No
STNCPY	String "n" copy. This function is used to extract parts from a string. When the enable is True, not more than 'Count' characters starting with character 'Index' are copied to the destination string.	No

STREQ	String Equal. When the enable input is True, source string (S1) is compared to source string (S2).	No
SUB	Subtract. The input values can be integer, double or float. The output will be the same type as the input.	Yes for all but floating-point
TDSTR	Time and Date to String. When the enable input is True, the time/date value is converted to a string. The input value can come from any valid time/date source. The output format is selectable.	No
TOF	Off Timer. TOF provides a delay of time from the falling edge of the input.	No
TOF-SIL	The SIL version of the Off Timer is the same as the normal TOF function, with the addition of duplicate storage for elapsed time variable.	Yes
TON	On Timer. TON provides a delay of time from the rising edge of the input	No
TON-SIL	The SIL version of the On Timer is the same as the normal TON function, with the addition of duplicate storage for elapsed time variable.	Yes
TRUNC	Truncate. The Input value is a float. The result will be a double; e.g. 123.456 = 123	No
UNPK16	Unpack. The input value is an integer. This function performs a bitwise unpacking of the input into Booleans.	Yes
UPKDT	Unpack Date/Time. This function performs an unpacking of a Date/Time to 6 integers.	No
XOR	Exclusive OR. The input values are Booleans. The output is True when the number of True inputs is odd.	Yes
XORW	XOR WORD. The input values can be integer or double. All values must be of the same type, and the result will be of the same type. This function performs a logical XOR of the inputs.	Yes



95-8599



FlexSonic® Acoustic  
Leak Detector



X3301 Multispectrum  
IR Flame Detector



PointWatch Eclipse® IR  
Combustible Gas Detector



FlexVu® Universal Display  
with GT3000 Toxic Gas Detector



Eagle Quantum Premier®  
Safety System



© 2022 Carrier. All rights reserved.



**Corporate Office**  
6901 West 110<sup>th</sup> Street  
Minneapolis, MN 55438 USA  
[www.det-tronics.com](http://www.det-tronics.com)

Phone: +1 952.941.6665  
Toll-free: +1 800.765.3473  
Fax: 952.829.8750  
[det-tronics@carrier.com](mailto:det-tronics@carrier.com)