

The manufacturer may use the mark:



Revision 3.0 August 05, 2022 Surveillance Audit Due June 30, 2025



Certificate / Certificat Zertifikat / 合格証

DET 1106064 C001

exida hereby confirms that the:

Eagle Quantum Premier (EQP) Safety System

Detector Electronics Corporation Minneapolis, MN - USA

Has been assessed per the relevant requirements of:

IEC 61508: 2010 Parts 1-3

and meets requirements providing a level of integrity to:

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; Route 1_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Safety Function:

The EQP Safety System detects flame, gas, smoke or other programmed hazardous condition and energizes an output per the programmed logic.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

Eagle Quantum Premier (EQP) Safety System

The following documents are a mandatory part of certification:

Assessment Report: DET 11-06-064 R002 V3R1 or later Safety Manual:

95-8599-10.1, or later



80 N Main St Sellersville, PA 18960

T-013, V7R2

Certificate / Certificat / Zertifikat / 合格証

DET 1106064 C001

Systematic Capability: SC 2 (SIL 2 Capable)
Random Capability: Type B Element

SIL 2 @ HFT=0; Route 1_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Systematic Capability:

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

IEC 61508 Failure Rates in FIT (1 FIT = 1 failure / 109 hours)

Device	$\lambda_{\sf sd}$	λ_{su}	λ_{dd}	λ_{du}	SFF
EQ300X – common	0	10	4517	74	98%
EQ3730EDIO – common	584	81	265	59	94%
EQ3730EDIO – per Input monitored for open and shorts	198	54	319	23	n/a
EQ3730EDIO – per Input monitored for open only	201	55	318	23	n/a
EQ3730EDIO – per monitored output	170	84	288	53	n/a
X3301 – Multispectrum IR Flame Detector with EQPSL communications	0	104	1545	55	97%
X3302 – Multispectrum IR Hydrogen Flame Detector with EQPSL communications	0	104	1545	55	97%
PIRECL – Eclipse Infrared Gas Detector with EQPSL communications	0	72	2894	147	95%
AIM – common	531	47	318	92	91%
AIM – per Input channel	114	20	244	26	n/a
UD10 DCU	274	134	755	80	n/a
UD10 DCU with CGS	352	100	951	88	n/a
LS2000 EQPSL	367	57	1320	59	97%
EQ3760ASM Smoke and Heat Module	386	191	743	56	96%
EQ3780HSDM High Speed Deluge Module	7761	694	3134	385	97%

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

Page 2 of 2