

Model EQP (Eagle Quantum Premier Fire and Gas Detection/Releasing System)

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

ATEX Directive: 2014/34/EU

Certificate No.: See the following page

Issued by: DEMKO/UL, Notified Body No. 0539

See the following page for details

EMC Directive: 2014/30/EU

EN 61000-6-2:2005 (HIM, EQ2230RSP, EQ3800PDM)

EN 61000-6-4:2007 (HIM, EQ2230RSP, EQ3800PDM)

EN 61000-6-2:2019 (All other modules)

EN 61000-6-4:2019 (All other modules)

RoHS Directive: 2011/65/EU + (EU) 2015/863

EN 63000:2018

QAN by:

UL International DEMKO A/S, NB. No. 0539

Borupvang 5A, 2750 Ballerup, Denmark

This declaration of conformity is issued under the sole responsibility of the manufacturer

Signature:



Yezihalem Mesfin

Senior Test and Approvals Manager

Date: 10/16/2025

Model	ATEX Certificate	ATEX Marking	Standard(s) of Compliance
EQ3XXX Series Controller EQ3710 Analog Input Module (AIM) EQ3730 Enhanced Discrete Input/Output Module (EDIO)	UL 20 ATEX 138864X	 II 3 G Ex nA nC IIC T4 Gc EN 60079-29-1 EN 60079-29-4	EN 60079-0:2018 EN 60079-15:2010 EN 60079-29-1:2016 EN 60079-29-4:2010
HART Interface Module (HIM) EQ3LTM LON Termination Module (LTM) EQ2230 RS485 Surge Protector Module (RSP)	UL 20 ATEX 138864X	 II 3 G Ex nA IIC T4 Gc	EN 60079-0:2018 EN 60079-15:2010
EQ24xxNE Network Extender	DEMKO 02 ATEX 131321X	 II 2 G Ex db IIC T6-T4 Gb EN 60079-29-1	EN 60079-0:2018 EN 60079-1:2014 EN 60079-29-1:2016+A1:2022 +A11:2022 EN 60079-29-4:2010
EQ2220 Ground Fault Monitor (GFM) EQ3700 Discrete Input/Output Module (DCIO) EQ3720 Relay Module (RM) Q3750 Addressable Smoke and Heat Module (ASH) EQ3760 Addressable Smoke Module (ASM) EQ3780 High Speed Deluge Module (HSDM)	UL 20 ATEX 138864X	 II 3 G Ex nA nC IIC T4 Gc	EN 60079-0:2018 EN 60079-15:2010
EQ3770 Input/Output Device Equipment Enclosure Solution (EIO)	DEMKO 17 ATEX 1840X	 II 2 G Ex db IIB+H2 T6	EN 60079-0:2018 EN 60079-1:2014
EQ3800 Power Distribution Module (PDM)	UL 20 ATEX 138864X	 II 3 G Ex nA IIC T3 Gc	EN 60079-0:2018 EN 60079-15:2010
EQ3900N Series Ex 'n' Enclosure	DEMKO 02 ATEX 133754X	 II 3 G Ex nA nC IIC T3 Gc EN 60079-29-1:2007  II 3 G Ex nA nC IIC T3 Gc  II 3 G Ex nA IIC T3 Gc	EN 60079-0:2018 EN 60079-15:2010 EN 60079-29-1:2007
PIRECL PointWatch Eclipse® Infrared Hydrocarbon Gas Detector (LON Output)	See PIRECL Declaration of Conformity, DEC-3023		
LS2000 FlexSight™ Line-of-Sight Infrared Hydrocarbon Gas Detector (LON Output)	See LS2000 Declaration of Conformity, DEC-3039		
UD10 FlexVu® Universal Display (DCU Emulator Output)	See UD10 Declaration of Conformity, DEC-3033		
X3301 Multispectrum Infrared Flame Detector (LON Output)	See X3301 Declaration of Conformity, DEC-1207		
X3302 Multispectrum Infrared Flame Detector (LON Output)	See X3302 Declaration of Conformity, DEC-1209		
X2200 Ultra Violet Flame Detector (LON Output) X5200 Ultra Violet/Infrared Flame Detector (LON Output) X9800 Infrared Flame Detector (LON Output)	See X2200/X5200/X9800 Declaration of Conformity, DEC-1208		